

A continuous run of 6mm dia high grade butyl mastic (min 25 yr guarantee) between panel and drip flashing and drip flashing and closure flashing

Self drilling self tapping primary fastener with minimum 15mm dia washers

0.7mm flashing sealed with gun applied sealant to wall as shown

Drip flashing

Soffit flashing fixed to drip flashing using colour matched rivets at maximum of 450mm centres and mastic pointed against brickwork

Rail must be sleeved to insure continuous air seal

Loose lay insulation

0.7mm Insulation retaining flashing standard white liner internal finish - Optional, required where junction is visible internally

All support steelwork by others

© Tata Steel UK Limited.

#### Trimapanel® U-values

Depth 70 = 0.31 W/m<sup>2</sup>K.  
Depth 90 = 0.24 W/m<sup>2</sup>K.  
Depth 120 = 0.17 W/m<sup>2</sup>K.

#### Junction 'psi' and 'fi' values

$\psi = 0.484$  W/mK.  
 $f = 0.702$

Stated calculation results are dependent on components being as shown.  
Computer modelled in accordance with EN ISO 10211



Tata Steel retain the right to amend the construction and technical specifications shown on this drawing without prior notice.

**TATA STEEL**

SALES TEL: 01244 892199  
TECHNICAL TEL: 01244 892133/34

[www.tatasteelconstruction.com](http://www.tatasteelconstruction.com)

PROJECT **Trimapanel® System  
Typical Details**

TITLE **Dado wall drip detail**

DRAWN BY	JCA	SCALE	NTS
----------	-----	-------	-----

APPROVED BY	DA	TOLERANCES	
-------------	----	------------	--

DATE	22/11/10	DWG. No.	W2-008-02-B
------	----------	----------	-------------