


Tata Steel retain the right to ammend the construction and technical specifications shown on this drawing without prior notice.



NOTE: Window to be installed as per manufacturers recommendations

TRIMAPANEL U-VALUES

70mm Core = 0.31 W/m² K.
 90mm Core = 0.24 W/m² K.
 120mm Core = 0.17 W/m² K.

Psi & f-Factor (Head) Y = 0.614W/mK. f = 0.735	Psi & f-Factor (Cill) Y = 0.163W/mK. f = 0.878
---	---

STATED CALCULATION RESULTS ARE DEPENDENT ON COMPONENTS BEING AS SHOWN
 Computer Modelled in accordance with EN ISO 10211



Building Systems UK
 A Tata Steel enterprise

Technical Office - TEL : 01244 892199
 www.buildingsystemsuk.co.uk

PROJECT
 Trimapanel System
 Typical Details

TITLE
 Window Head & Cill

DRAWN BY LK	SCALE NTS
----------------	--------------

APPROVED BY PS	TOLERANCES
-------------------	------------

DATE 21/06/23	DRG. No. W2-011-03
------------------	-----------------------

All support steelwork by others