


Tata Steel retain the right to amend the construction and technical specifications shown on this drawing without prior notice.



All support steelwork by others

© Building Systems UK

### TRISOBUILD™ U-VALUES

The depth below refers to both the minimum bracket & insulation height to achieve the stated 'U' value when using a LP1000 liner

Depth 140 = 0.30 W/m <sup>2</sup> K.	Depth 240 = 0.18 W/m <sup>2</sup> K.
Depth 160 = 0.26 W/m <sup>2</sup> K.	Depth 260 = 0.16 W/m <sup>2</sup> K.
Depth 180 = 0.23 W/m <sup>2</sup> K.	Depth 280 = 0.15 W/m <sup>2</sup> K.
Depth 200 = 0.21 W/m <sup>2</sup> K.	Depth 300 = 0.14 W/m <sup>2</sup> K.
Depth 220 = 0.19 W/m <sup>2</sup> K.	

### Junction 'psi' and 'f' values

$\Psi = 0.022$  W/mK.  
 $f = 0.97$

Stated calculation results are dependent on components being as shown.  
 Computer modeled in accordance with EN ISO 10211



**Building Systems UK**  
 A Tata Steel enterprise

Technical Office - TEL : 01244 892199  
[www.buildingsystemsuk.co.uk](http://www.buildingsystemsuk.co.uk)

PROJECT

Typical Trisobuild  
 VW Details

TITLE

Roof to Wall Junction

DRAWN BY

LK

SCALE

NTS

APPROVED BY

PS

TOLERANCES

DATE

01/06/23

DRG. No.

W1-020-02